

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

8 / 21 / 08

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: GARY AND CHRISTINA KAMINSKY

Address of Inspected Unit: 125 South Cove Rd Unit # _____

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Heat N Glo - GAS FIREPLACE INSERT
Location of Heating System: Family Room

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print)
Don Crossman

Licensure for plumbing & heating?
 Yes No License #: MP-3945

Certification for gas equipment?
 Yes No Cert #: GN-2091

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Don

Comments: _____

Recommend clean and service by dealer, found no CO orums glass or arand unit

CARBON READING PRINTOUT

SEE READINGS ON ATTACHED CHIMNEY SWEEP INVOICE

CHIMNEY SWEEP FIREPLACE
 3113 SHELBURNE ROAD
 SHELBURNE, VT. 05482
 PH# 802-985-4900

PRINT DATE: 11-04-08 11:22 PAGE: 1 WORK ORDER #: J05718
 DATE STARTED: 08-28-08 DATE COMPLETED: 08-29-08 CLERK: 021
 RTE#: ETA:
 AUDIT BR: SERV SRVC BR: SERV ORIG BR: SERV LOC/UNIT: SERV
 PO#- MASTER TECH: 011

STATUS: WORKORDER UPDATED AS TICKET# J05718
 TYPE: CUSTOMER/FIELD SERVICE

BILL GARY KAMINSKY
 TO: 125 SOUTH COVE RD.
 BURLINGTON, VT. 05401

SHIP GARY KAMINSKY
 TO: 125 SOUTH COVE RD.
 BURLINGTON, VT. 05401

HOME PHONE: 802-651-0585

HOME PHONE: 802-651-0585

ITEM SERVICED: AT GRAND	DESC: DV, LP	BRAND: HNG	WARRANTY: MFG	EXT	REC
SERIAL #: 6746-498	RECEIVED PROOF OF WARRANTY:	AUTH #:	LABOR	N	N
PURCHASE DATE:	SELLING DEALER: CHIMNEY SWEEP	SHELBURNE, VT	PARTS	N	N
			OTHER	N	N

CUSTOMER COMMENTS: PERFORM ANNUAL SAFETY INSPECTION

READINGS

SERVICE PERFORMED: TCUPLE 210. TPILE 507MV OFF, 208MV ON. CO = 0PPM. [RESSURE 11" WC IN, 9.5" WC OUT. INSPECTION
 DONE, UNIT IS OK.

QUANTITY	PART	BRAND	PART DESCRIPTION	EMPLOYEE# /SERIAL#	WRTY TYPE	LINE STAT	COMMENT	OPT CODE	P/U BRCH	TOTAL SELLING PR
1.00	ASI	REPLA	ANNUAL SAFETY INSPECTION	EMP: 011	NO	I	*** INSTALLED **			109.95

TOTAL LABOR: 109.95

CASH/CK: 109.95

CR CARD: .00

CHARGE: .00

OTHER: .00

TOTAL PARTS:

DELIVERY :

SALES TAX :

GRAND TOTAL: 109.95

CUSTOMER SIGNATURE

TECHNICIAN SIGNATURE