

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc. TAG# \_\_\_\_\_

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:  
6 / 1 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Denise Vignoe

Address of Inspected Unit: 14 East Terrace, S. Burlington Unit # \_\_\_\_\_

Heating System(s) Type:  
*(Check all that Apply)*  
Space Heater  
Warm Air Furnace  
Wall Mount Furnace  
 Boiler  
Gas Fireplace  
Other

Fuel Type:  
 Natural Gas  
Oil  
Propane

Venting System(s):  
*(Check all that Apply)*  
Direct Vent  
B-Vent  
 Masonry \*  
Other  
  
\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Slant Fin L30-P Nat Conv. from oil

Location of Heating System: Basement

System Passed    System Failed    If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
*(Please Print)*  
Travis Adams

Licensure for plumbing & heating?  
Yes    No License #: \_\_\_\_\_

Certification for gas equipment?  
 Yes    No Cert #: GB-1323

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: Exterior Masonry  
Chimney w/ clay liner.  
Tag # 13089



BACHARACH, INC.  
Fyrite Insight  
SN: PX1280

Time: 11:11:18 AM  
Date: 08/01/11

Fuel  
Nat Gas

O <sub>2</sub>	3.1 %
CO	59 ppm
Eff	86.8 %
CO <sub>2</sub>	10.1 %
T-STK	232 °F
T-AIR	74.6 °F
EA	15.2 %
CO(O)	69 ppm

Comments: \_\_\_\_\_