

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc. TAG# 13158

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

4 / 15 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 190 Howard St Unit # 1

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: American Standard Aux 100

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
Yes No License #: PS-163


Certification for gas equipment?
Yes No Cert #: GB 448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: _____

benoure.....
#.25.....
.....



BACHARACH, INC.
Fvrite Insight
SN: PX1278

Time: 11:19:40 AM
Date: 04/15/11

Fuel
Nat Gas

O ₂	12.1 %
CO	16 ppm
EFF	93.7 %
CO ₂	5.0 %
T-SIK	99 °F
T-AIK	56.3 °F
EA	121.2 %
CO(O)	38 ppm

Comments: _____

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc. TAG# 18157

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
4 / 15 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 190 Howard St Unit # 2

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Empire DV-60-SPP

Location of Heating System: Entry

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
Yes No License #: PS-163

Certification for gas equipment?
Yes No Cert #: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments:

benoure.....
#.25.....



BACHARACH, INC.
Fyrite Insight
SN: PX1278

Time: 08:58:54 AM
Date: 04/15/11

	Fuel
	Nat Gas
O ₂	8.5 %
CO	16 ppm
Eff	74.9 %
CO ₂	7.0 %
T-S1K	510 °F
T-AIR	46.2 °F
EA	60.7 %
CO(O)	27 ppm

Comments:
