

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

7 / 17 / 08

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Carlin Fox

Address of Inspected Unit: 62 Henry St Unit # 2

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

** All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Weil mclain EG/PEG-40

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeffrey Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert #: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeffrey Ryan

Comments: _____

TAG 5571

C125 1.3

TEST 21
DATE 07/17/08
TIME 10:56:05

COMBUSTION

FUEL	NAT	GAS
O2 %		6.1
CO2 %		8.4
CO PPM		16
FLUE °F	324.7	
INLT °F	73.8	
NETT °F	251.2	

EFF (G)	83.0
LOSSES	17.0
XAIR %	41.2

CO/CO2	0.0002
CO AIR FREE	25
PRS hPA	0.04

Customer: _____

Appliance: _____

Ref: _____