

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:  
5 / 18 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 202 Howard St Unit # 1

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler**
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent**
- B-Vent
- Masonry \*
- Other

*\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: CG5-1-PIN  
Location of Heating System: Basement/Att./1st fl.

**System Passed**      System Failed      If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* Jeff Ryea

Licensure for plumbing & heating?  
  
Yes      No License #: PS 163

Certification for gas equipment?  
  
 Yes      No Cert#: 68448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: Tag # 5558

**C125 1-Z**  
**Benoure**

TEST      71  
DATE      05/18/09  
TIME      09:39:21

**COMBUSTION**

		NAT	GAS
FUEL			
O2 %		8.9	
CO2 %		6.3	
CO ppm		22	
FLUE °F		243.4	
INLT °F		65.4	
NETT °F		178.0	

EFF (G)	84.1
LOSSES	15.9
XAIR %	74.1

CO/CO2      0.0003  
CO AIR FREE      38

PRS    hPA      0.07

Customer .....  
Appliance .....  
Ref. ....  
.....