

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:  
5 / 18 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 202 Howard St Unit # 2

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler**
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent**
- B-Vent
- Masonry \*
- Other

*\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: CGS-4-PIN

Location of Heating System: Basement / Utility

System Passed

System Failed

If System Failed, Next Appt:    /   /   

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)*  
Jeff Ryan

Licensure for plumbing & heating?  
Yes No License #: PS-163

Certification for gas equipment?  
 Yes No Cert#: CS 448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: TAJ 5559

C125 1.2  
Benoure

TEST 72  
DATE 05/18/09  
TIME 09:41:21

COMBUSTION

FUEL	NAT	GAS
O2 %		10.3
CO2 %		6.0
CO ppm		12
FLUE °F		234.7
INLT °F		65.4
NETT °F		169.3

EFF (G)	83.7
LOSSES	16.3
XAIR %	97.1

CO/CO2 0.0002  
CO AIR FREE 23

PRS hPA 0.10

Customer .....

Appliance .....

Ref. ....