

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

5 / 18 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 202 Howard St. Unit # 3

### Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

### Fuel Type:

- Natural Gas
- Oil
- Propane

### Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: CG5-4-PIN

Location of Heating System: Basement / utility

System Passed      System Failed      If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
(Please Print) Jeff Ryea

Licensure for plumbing & heating?  
Yes      No License #: PS-163

Certification for gas equipment?  
 Yes      No Cert#: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: TAG # 5560

C125 1.2  
Benoure

TEST 73  
DATE 05/18/09  
TIME 09:49:38

### COMBUSTION

FUEL	NAT	GAS
O2 %		7.6
CO2 %		7.6
CO ppm		19
FLUE °F		279.4
INLT °F		65.4
NETT °F		214.0

EFF (G) 83.5  
LOSSES 16.5  
XAIR % 57.1

CO/CO2 0.0002  
CO AIR FREE 29

PRS hPA 0.21

Customer .....

Appliance .....

Ref. ....