

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 20 North Union Unit # 1

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: CGS-4

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert#: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: TAG # 5548

C125 1.3
BENOURE P&H V31

TEST 87
DATE 05/06/09
TIME 15:16:10

COMBUSTION

FUEL	NAT	GAS
O2 %		12.8
CO2 %		4.6
CO ppm		20
FLUE °F		226.6
INLT °F		121.9
NETT °F		104.7

EFF (G) 85.2
LOSSES 14.8
XAIR % 158.0

CO/CO2 0.0004
CO AIR FREE 51

PRS INH2O 0.00

Customer
Appliance
Ref.