

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 20 North Union Unit # 2

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: CGS-4

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert#: GB448

I have inspected the heating and venting system (s) and
certify that it is/they are installed properly and is/are
operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: TAG # 5547

C125 1-3
BENOURE P&H V31

TEST	86
DATE	05/06/09
TIME	15:14:28

COMBUSTION

FUEL	NAT	GAS
O2 %		9.7
CO2 %		6.4
CO ppm		20
FLUE °F		231.5
INLT °F		121.9
NETT °F		109.6

EFF (G)	86.3
LOSSES	13.7
AIR %	86.6

CO/CO2	0.0003
CO AIR FREE	37

PRS INH2O 0.00

Customer

Appliance

Ref.