

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

5 / 18 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 21 Hungereford Terrace Unit # \_\_\_\_\_

**Heating System(s) Type:**  
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \* Line 2008
- Other

\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: w/m  
Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
(Please Print) Jeff Ryea

Licensure for plumbing & heating?  
Yes No License #: PS-163

Certification for gas equipment?  
 Yes No Cert#: GB-448

I have inspected the heating and venting system (s) and  
certify that it is/they are installed properly and is/are  
operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: TAG # 5582

C 125 1.2  
Benoure

TEST 76  
DATE 05/18/09  
TIME 11:01:45

**C COMBUSTION**

| FUEL    | NAT | GAS   |
|---------|-----|-------|
| O2 %    |     | 11.9  |
| CO2 %   |     | 5.1   |
| CO PPM  |     | 61    |
| FLUE OF |     | 430.4 |
| INLT OF |     | 65.4  |
| NETT OF |     | 365.0 |

EFF (G) 74.3  
LOSSES 25.7  
XAIR % 132.2

CO/CO2 0.0011  
CO AIR FREE 141

PRS hPA 0.17

Customer .....

Appliance .....

Ref: .....