

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:

8 / 16 / 12

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 286 Pearl ST Unit # 1

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys tiled or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: _____

Location of Heating System: _____

System Passed

System Failed

If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print)

Tim Trombley

Licensure for plumbing & heating?

Yes No License #: PM-3137

Certification for gas equipment?

Yes No Cert #: GB-1996
OIL # OS-631

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: _____

FUEL	NAT	GAS
O2 %		20.9
CO2 %		-0>-
CO PPA		00
FLUE	-F	134.3
INLT	-F	76.0
NETT	-F	58.3
EFF (G)		-0>-
LOSSES		-0>-
XAIR %		-0>-
CO/CO2	0.0000	
CO AIR FREE	-0>-	
PRS	INH2O	0.00

APT #1
 Customer
286 Pearl
 App:ance
City JOA
 Ref
17563

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
6 / 7 / 12

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: GENE RICHARDS

Address of Inspected Unit: 286 PEARL Unit # 2

Heating System(s) Type:
 (Check all that Apply)
 Space Heater
 Warm Air Furnace
 Wall Mount Furnace
 Boiler
 Gas Fireplace
 Other

Fuel Type:
 Natural Gas
 Oil
 Propane

Venting System(s):
 (Check all that Apply)
 Direct Vent
 B-Vent
 Masonry *
 Other
 *All masonry chimneys lined or unlined
 need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: HEAT N GLO SL-550TRSC
 Location of Heating System: LIVING ROOM

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print)
 Scott Gagnon

Licensure for plumbing & heating?
 Yes License #: PM-3563

Certification for gas equipment?
 Yes Cert #: GB-922

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Scott Gagnon

Comments: DIRECT VENT
CANNOT TAKE
COMBUSTION READING
CHECK ROOM AIR
NO CARBON MONOXIDE

C125 1 3

DATE 06/07/12
 TIME 14:50:41
 FUEL Nat Gas
 COMBUSTION

 LOG 01
 O2 % 21.0
 CO2 % -0>-
 CO ppm 00
 PLUE °F 74.9
 INLT °F 70.6
 NETT °F 4.3
 EFF (G) -0>-
 LOSSES -0>-
 XAIR % -0>-
 CO/CO2 0.0000
 CO AIR FREE -0>-
 PR5 inH2O -0.02

.....
 Customer

 Appliance

 Ref.

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:

6 / 7 / 12

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: GENE RICHARDS

Address of Inspected Unit: 286 PEARL ST. Unit # 3

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

* All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: TRAVEL - BEDBREDFEST

Location of Heating System: KITCHEN

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print)
 Scott Gagnon

Licensure for plumbing & heating?

Yes License #: PM-3563

Certification for gas equipment?

Yes Cert #: GB-922

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Scott Gagnon

Comments: NO ROOM CO

C125 1.3

DATE 06/07/12
 TIME 15:09:29

FUEL Nat Gas

COMBUSTION

LOG 02

O2 % 21.0
 CO2 % -0.0
 CO ppm 00
 FLUE °F 73.8
 INLT °F 73.5
 NETT °F 0.3

EFF (G) -0.0
 LOSSES -0.0
 XAIR % -0.0

CO/CO2 0.0000
 CO AIR FREE -0.0

PRS inH2O 0.00

Customer

Appliance

Ref.