

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
5 / 21 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 286 Pearl Unit # 1

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: 3403565512
 Location of Heating System: Apt 1

System Passed

System Failed

If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print) Jeff Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert#: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: Tag # 5566

C125 1-2
 Benoure

TEST 85
 DATE 05/18/09
 TIME 13:35:44

COMBUSTION

FUEL	NAT	GAS
O2 %		20.8
CO2 %		-0>-
CO PPM		00
FLUE °F		130.3
INLT °F		60.5
NETT °F		70.4

EFF (G) -0>-
 LOSSES -0>-
 XAIR % -0>-
 CO/CO2 0.0000
 CO AIR FREE -0>-
 PRS hPA 0.00

#1 286 Pearl
 Customer # 3403565512
 Appliance Tag # 5566
 Ref.