

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
5 / 18 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments
 Address of Inspected Unit: 286 Pearl Unit # # 3

Heating System(s) Type: (Check all that Apply) Space Heater Warm Air Furnace Wall Mount Furnace Boiler <input checked="" type="checkbox"/> Gas Fireplace Other	Fuel Type: <input checked="" type="checkbox"/> Natural Gas Oil Propane	Venting System(s): (Check all that Apply) <input checked="" type="checkbox"/> Direct Vent B-Vent Masonry * Other <small>*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep</small>
--	--	---

Model # of Boiler/Furnace/Fireplace: Boiler / Breakfast
 Location of Heating System: Apt

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print) Jeff Rye

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert#: GB 448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Rye

Comments: TAG # 7064

C125 1.2
 Benoure

TEST 56

DATE 05/18/09
 TIME 13:46:31

COMBUSTION

FUEL	NAT	GAS
O2 %		20.8
CO2 %		-0.7
CO ppm		00
FLUE °F		140.4
INLT °F		60.5
NETT °F		79.9
EFF (G)		-0.7
LOSSES		-0.7
XAIR %		-0.7
CO/CO2		0.0000
CO AIR FREE		-0.7
PRS hPA		0.01

286 Pearl # 3
 Customer
Boiler / Breakfast
 Appliance
TAG # 7064
 Ref.