

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7 / 19 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 300 Colchester Ave Unit # \_\_\_\_\_

Heating System(s) Type:  
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):  
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: GV-4

Location of Heating System: Basement

System Passed      System Failed      If System Failed, Next Appt:    /    /   

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
(Please Print) Jeff Ryan

Licensure for plumbing & heating?  
Yes      No License #: P5-163

Certification for gas equipment?  
 Yes      No Cert#: 63448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: Tag # 5578

0125 1.3  
BENOURE P&H V31

TEST 90  
DATE 08/10/09  
TIME 12:33:28

C COMBUSTION

FUEL	NAT GAS
OE %	8.7
CO2 %	9.0
O2 ppm	18
FLUE °F	131.0
INLT °F	59.4
NETT °F	122.1
EFF (G)	87.1
LOSSES	12.9
XAIR %	21.8
CO/CO2	0.0001
CO AIR FREE	16
PRS InH2O	0.00

Customer  
Appliance  
Ref.