

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 18 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 32 South Union St. Unit # _____

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: G-V-3

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryea

Licensure for plumbing & heating?
Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert#: GB-418

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: Tag # 5533

C125 1.2
Benoure

TEST 82
DATE 05/18/09
TIME 12:09:13

COMBUSTION

FUEL	NAT	GAS
O2 %		3.1
CO2 %		10.1
CO ppm		15
FLUE °F		156.8
INLT °F		63.2
NETT °F		93.6
EFF (G)		87.9
LOSSES		12.1
XAIR %		17.4
CO/CO2	0.0001	
CO AIR FREE	17	
PRS hPA		0.02

Customer: _____
Appliance: _____
Ref.: _____