

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

9 / 2 / 09

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 343 College St. Bu Unit # 1

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

** All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Ultra 80

Location of Heating System: utility RM

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print)
Jeff Ryea

Licensure for plumbing & heating?

Yes No License #: PS-163

Certification for gas equipment?

Yes No Cert #: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: Tag # 7068

125 1-2
hours

TEST 63
DATE 09/02/09
TIME 10:22:18

COMBUSTION

FUEL	NAT	GAS
O2 %		5.8
CO2 %		8.6
CO PPM		19
FLUE "F"		159.1
INLT "F"		72.4
NETT "F"		86.7

EFF (G) 87.7
LOSSES 12.3
XAIR % 38.4

CO/CO2 0.0002
CO AIR FREE 26

PRS hPA 0.03

Customer

Appliance

Ref.