

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:  
9 / 2 / 09

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 343 College St Unit # 2

Heating System(s) Type:  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

*\* All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Ultra 80

Location of Heating System: Utility Rm

System Passed     System Failed    If System Failed, Next Appt:      /      /     

Company Conduction Inspection:  
 Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
*(Please Print)* Jeff Ryan

Licensure for plumbing & heating?  
 Yes     No License #: PS-163

Certification for gas equipment?  
 Yes     No Cert #: GS-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: Tag # 7069

0.125 1.2  
 hours

TEST 62  
 DATE 09/02/09  
 TIME 10:28:13

COMBUSTION		
FUEL	NAT	GAS
O2 %		5.8
CO2 %		8.8
CO PPM		25
FLUE °F		151.9
INLT °F		72.4
NETT °F		79.5
EFF (G)		87.9
LOSSES		12.1
XAIR %		38.4
CO/CO2		0.0002
CO AIR FREE		34
PRS	hPA	0.00

Customer  
 Appliance  
 Ref.