

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

5 / 18 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 34 Buell St. Unit # \_\_\_\_\_

**Heating System(s) Type:**

*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**

*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

*\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: PT 9D20N120UPHD (York)

Location of Heating System: Basement

System Passed      System Failed      If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* Jeff Ryea

Licensure for plumbing & heating?  
Yes      No License #: PS-163

Certification for gas equipment?  
X Yes      No Cert#: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: Tag it 5535

C125 1.2  
Benoure

---

TEST      84

DATE      05/18/09

TIME      12:33:51

COMBUSTION

FUEL	NAT	GAS
O2 %		13.3
CO2 %		4.3
CO PPM		08
FLUE "F		93.3
INLT "F		63.2
NETT "F		30.1
EFF (G)		88.6
LOSSES		11.4
XAIR %		175.0
CO/CO2		0.0001
CO AIR FREE		22
PRS	hPA	0.03

Customer

Appliance

Ref.