

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 34 South Union St Unit # _____

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: GV-3
 Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 X Yes No Cert#: GB-418

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: Tag # 5534

C125 1.2
 Benoure

TEST	83
DATE	05/18/09
TIME	12:17:28

COMBUSTION

FUEL	NAT	GAS
O2 %	21.2	21.2
CO2 %	9.7	9.7
CO ppm	03	03
FLUE %F	177.1	177.1
INLT %F	63.2	63.2
NETT %F	113.9	113.9
EFF (G)	87.2	87.2
LOSSES	12.8	12.8
XAIR %	22.9	22.9
CO/CO2	0.0000	0.0000
CO AIR FREE	11	11
PRS hPA	0.02	0.02

Customer

Appliance

Ref.