

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:  
5 / 15 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 355 Pearl Unit # 2

**Heating System(s) Type:**  
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

*\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: GW-4  
 Location of Heating System: Utility Room

System Passed      System Failed      If System Failed, Next Appt:    /   /   

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
 (Please Print) Jeff Ryan

Licensure for plumbing & heating?  
 Yes      No License #: PS-163

Certification for gas equipment?  
 Yes      No Cert#: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: TAG # 5573

C125 1.3  
 BENOURE P&H V31

TEST 80  
 DATE 05/06/09  
 TIME 14:29:31

C/

COMBUSTION	
FUEL	NAT GAS
O2 %	4.4
CO2 %	9.4
CO PPM	13
FLUE °F	213.0
INLT °F	79.2
NETT °F	133.8
EFF (%)	86.6
LOSSES	13.4
XAIR %	26.7
CO/CO2	0.0001
CO AIR FREE	16
PRS INH2O	0.00

Customer .....

Appliance .....

Ref. ....