

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 355 Pearl Unit # 3

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: GV-#3

Location of Heating System: utility RM

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print)
Jeff Rye

Licensure for plumbing & heating?
Yes No License #: PS 163

Certification for gas equipment?
X Yes No Cert#: GS-148

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: Tag # 5577

C125 1.3
BENOURE P&H V31

TEST 85
DATE 05/06/09
TIME 14:46:20

CA COMBUSTION

FUEL	NAT	GAS
O2 %		3.3
CO2 %		10.0
CO ppm		21
FLUE °F		192.8
INLT °F		79.2
NETT °F		113.6

EFF (G)	87.3
LOSSES	12.7
XAIR %	18.8

CO/CO2	0.0082
CO AIR FREE	24

PRS	INH2O	0.00
-----	-------	------

Customer

Appliance

Ref.