

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 355 Pearl St Unit # 5

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: GV-#3

Location of Heating System: Utility Rm

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
Yes No License #: Ps 163

Certification for gas equipment?
 Yes No Cert#: CB-148

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: TAG 5575

C125 1.3
BENOURE P&H V31

TEST 83
DATE 05/06/09
TIME 14:36:20

COMBUSTION

FUEL	NAT	GAS
O2 %		9.6
CO2 %		9.8
CO PPM		14
FLUE °F	182.3	
INLT °F	79.0	
NETT °F	103.7	

EFF (G) 87.5
LOSSES 12.5
XAIR % 29.0

CO/CO2 0.0001
CO AIR FREE 16
PRS Inh2O 0.00

Customer
Appliance
Ref.