

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 355 Pearl St Unit # 6

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: GV-3

Location of Heating System: utility RM

System Passed

System Failed

If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

Jeff Ryan

Licensure for plumbing & heating?

Yes No License #: PS-163

Certification for gas equipment?

Yes No Cert#: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: TR # 5574

C125 1.3
BENDURE P&H V31

TEST	82
DATE	05/06/09
TIME	14:33:10

COMBUSTION

FUEL	NAT	GAS
O2 %		2.9
CO2 %		10.2
CO ppm		23
FLUE °F		189.0
INLT °F		79.2
NETT °F		109.8

EFF (G)	87.5
LOSSES	12.5
XAIR %	16.1

CO/CO2	0.0002
CO AIR FREE	28

PRS INH2O 0.00

Customer

Appliance

Ref.