

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 361 Pearl St. Burlington VT Unit # 1

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Ultra 80

Location of Heating System: Utility Room

System Passed System Failed If System Failed, Next Appt: / /


Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Travis Adams

Licensure for plumbing & heating?
Yes No License #: _____

Certification for gas equipment?
 Yes No Cert#: GB-1323

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: 

Comments: Tag # 5561

C125 1.3
BENOURE P&H V31

TEST 72
DATE 05/06/09
TIME 11:31:26

COMBUSTION

FUEL	NAT	GAS
O2 %		5.2
CO2 %		8.9
CO PPM		28
FLUE °F		157.9
INLT °F		72.9
NETT °F		85.0

EFF (G)	87.8
LOSSES	12.2
XAIR %	33.1

CO/CO2	0.0003
CO AIR FREE	37

PRS INH2O 0.01

Customer

Appliance

Ref.