Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection: 5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 361 Pearl St. Burlington VT Unit # 3

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- X Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Ultra 80
Location of Heating System: Utility Room

X System Passed System Failed If System Failed, Next Appt: ____/____/____

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Travis Adams

Licensure for plumbing & heating?

Yes No License #: ____

Certification for gas equipment?

X Yes No Cert#: G-B- 1323

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [signature]

Comments: Tag # 5563

C125 1.3
BENOURE P&H V31

TEST	73
DATE	05/06/09
TIME	11:40:15

COMBUSTION

FUEL		NAT GAS
O2	%	5.2
CO2	%	8.9
CO	PPM	28
FLUE	°F	169.4
INLT	°F	72.9
NETT	°F	96.5
EFF (G)		87.5
LOSSES		12.5
XAIR	%	33.1
CO/CO2		0.0003
CO AIR FREE		37
PRS	InH2O	0.03

Customer

Appliance

Ref.

Benoure Plumbing & Heating, Inc.