

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

5 / 15 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 361 Pearl St Unit # 4

**Heating System(s) Type:**  
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Ultra 80  
Location of Heating System: utility Rm.

System Passed

System Failed

If System Failed, Next Appt:     /    /    

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
(Please Print) Jeff Rye

Licensure for plumbing & heating?

Yes No License #: PS-163

Certification for gas equipment?

Yes No Cert#: GB-448

I have inspected the heating and venting system (s) and  
certify that it is/they are installed properly and is/are  
operating safely at this time.

Signature of Inspector: [Signature]

Comments: TAG # 5537

C125 1.3  
BENOURE P&H V31

TEST	77
DATE	05/06/09
TIME	11:47:54

COMBUSTION

FUEL	NAT	GAS
O2 %		5.5
CO2 %		8.8
CO PPM		27
FLUE °F		184.9
INLT °F		72.9
NETT °F		112.0
EFF (G)		67.1
LOSSES		12.9
XAIR %		35.7

CO/CO2	0.0003
CO AIR FREE	36
PRS InH2O	0.04

Customer

Appliance

Ref.