

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 361 Pearl St Unit # 6

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: ULTRA 80

Location of Heating System: Utility Rm

System Passed

System Failed

If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

Jeff Ryan

Licensure for plumbing & heating?

Yes No License #: PS-163

Certification for gas equipment?

Yes No Cert#: G-5-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: Tag # 5538

C125 1-3
BENOURE P&H V31

TEST 78
DATE 05/06/09
TIME 11:45:00

COMBUSTION

FUEL	NAT	GAS
O2 %		5.6
CO2 %		6.8
CO PPM		26
FLUE °F		173.1
INLT °F		72.9
NETT °F		106.2
EFF (G)		87.3
LOSSES		12.7
XAIR %		35.7
CO/CO2		0.0002
CO AIR FREE		35
PRS Inh20		0.04

Customer

Appliance

Ref.

Benoure Plumbing & Heating, Inc.