

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

5 / 15 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 361 Pearl St Unit # 7

Heating System(s) Type:  
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):  
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Ultra 80

Location of Heating System: utility Rm

System Passed      System Failed      If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
(Please Print) Jeff Ryea

Licensure for plumbing & heating?  
Yes      No License #: PS-163

Certification for gas equipment?  
 Yes      No Cert#: GB-448

I have inspected the heating and venting system (s) and  
certify that it is/they are installed properly and is/are  
operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: TAG # 5540

C125 1.3  
BENOURE P&H V31

TEST 74  
DATE 05/06/09  
TIME 11:41:35

### COMBUSTION

FUEL	NAT	GAS
O2 %		5.3
CO2 %		8.9
CO ppm		30
FLUE °F	154.1	
INLT °F	72.9	
NETT °F	61.2	

EFF (G)	87.9
LOSSES	12.1
XAIR %	34.0

CO/CO2	0.0003
CO AIR FREE	40

PRS INH2O 0.03

Customer: \_\_\_\_\_

Appliance: \_\_\_\_\_

Ref: \_\_\_\_\_