

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 15 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 361 Pearl St Unit # 8

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Ultra 80

Location of Heating System: utility Rm

System Passed

System Failed

If System Failed

Next Annt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

Jeff Ryan

Licensure for plumbing & heating?

Yes

No License #:

PS-163

Certification for gas equipment?

Yes

No Cert#:

GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector:

Jeff Ryan

Comments:

TAG # 5539

0125 1.3
BENOURE P&H V31

TEST 75
DATE 05/06/09
TIME 11:43:00

COMBUSTION

FUEL NAT GAS

O2 % 5.0
CO2 % 9.0
CO PPM 32
FLUE °F 187.0
INLT °F 72.0
NETT °F 114.0

EFF (G) 87.0
LOSSES 13.0
XAIR % 31.4

CO/CO2 0.0003
CO AIR FREE 42

PR3 Inh20 0.04

Customer

Appliance

Ref.