



VERMONT DEPARTMENT OF PUBLIC SAFETY
DIVISION OF FIRE SAFETY
 Office of the State Fire Marshal, State Fire Academy and State Haz-Mat Team



CERTIFICATE OF BOILER & PRESSURE VESSEL INSPECTION

**VERMONT FIRE & BUILDING
 SAFETY CODE**
BOILER/PV PROOF OF INSPECTION
 INSP. NO. **99219**

INSPECTION DATE _____ EXP. DATE _____

VIOLATIONS
 YES NO CORRECTED

DATE _____ INITIALS _____

**DIVISION OF FIRE SAFETY
 VERMONT DEPT. OF PUBLIC SAFETY**

Boiler Pressure Vessel External Internal

Structure Name:	430 NEST EGGS LLC			
911 Address:	430 SHELBURNE RD. S. BURLINGTON VT			
VT State ID #:	36693	NB #:	71440	
Manufacturer:	AIC	Year:	2012	Object Type: COLL WT BOILER
MAWP:	300psi	S/V- R/V Set Pressure:	300psi	
Insurance Co.:	H.S.B	Inspector Name (Print):	JL MAURER	
VT Comm. #:	963	Inspector Signature:		

REINSPECTIONS

INSPECTION TYPE: INT/EXT/OPERATING	DATE Mo/Day/Year	INSPECTOR NAME	VERMONT COMM. #	VIOLATIONS FOUND

**THIS OBJECT MAY NOT BE OPERATED LEGALLY UNLESS THIS CERTIFICATE
 IS POSTED UNDER GLASS IN A CONSPICUOUS PLACE IN ENGINE OR BOILER ROOM**

*****Report any accident, incident or explosion to 802-479-4434 *****
 (1-888-870-7888 outside of normal business hours)



VERMONT DEPARTMENT OF PUBLIC SAFETY
DIVISION OF FIRE SAFETY
 Office of the State Fire Marshal, State Fire Academy and State Haz-Mat Team



CERTIFICATE OF BOILER & PRESSURE VESSEL INSPECTION

**VERMONT FIRE & BUILDING
 SAFETY CODE
 BOILER/PV PROOF OF INSPECTION**
 INSP. NO. **99220**

INSPECTION DATE _____ EXP. DATE _____

VIOLATIONS
 YES NO CORRECTED

DATE	INITIALS

**DIVISION OF FIRE SAFETY
 VERMONT DEPT. OF PUBLIC SAFETY**

Boiler Pressure Vessel External Internal

Structure Name:	430 NEST EGGS LLC			
911 Address:	430 SHREBURNER RD. S. BURLINGTON VT			
VT State ID #:	36684	NB #:	78686	
Manufacturer:	AIC	Year:	2012	Object Type: COL WT BOILER
MAWP:	32PSI	S/V- R/V Set Pressure:	32PSI	
Insurance Co.:	H.S.B	Inspector Name (Print):	J. MALBORG	
VT Comm. #:	963	Inspector Signature:		

REINSPECTIONS

INSPECTION TYPE: INT/EXT/OPERATING	DATE Mo/Day/Year	INSPECTOR NAME	VERMONT COMM. #	VIOLATIONS FOUND

**THIS OBJECT MAY NOT BE OPERATED LEGALLY UNLESS THIS CERTIFICATE
 IS POSTED UNDER GLASS IN A CONSPICUOUS PLACE IN ENGINE OR BOILER ROOM**

*****Report any accident, incident or explosion to 802-479-4434 *****
 (1-888-870-7888 outside of normal business hours)



VERMONT DEPARTMENT OF PUBLIC SAFETY
DIVISION OF FIRE SAFETY
 Office of the State Fire Marshal, State Fire Academy and State Haz-Mat Team



CERTIFICATE OF BOILER & PRESSURE VESSEL INSPECTION

**VERMONT FIRE & BUILDING
 SAFETY CODE**
BOILER/PV PROOF OF INSPECTION
 INSP. NO. **99221**

INSPECTION DATE EXP. DATE

VIOLATIONS
 YES NO CORRECTED DATE INITIALS

**DIVISION OF FIRE SAFETY
 VERMONT DEPT. OF PUBLIC SAFETY**

Boiler Pressure Vessel External Internal

Structure Name:	430 WEST EGAN LLC			
911 Address:	430 SHREVEUR RD. S. BURLINGTON VT			
VT State ID #:	36685	NB #:	-N/A-	
Manufacturer:	W. MCCLAW	Year:	2004	Object Type: CAST-IRON BLD.
MAWP:	50PSI	S/V- R/V Set Pressure:	30PSI	
Insurance Co.:	H.S.R	Inspector Name (Print):	J. MELBORNE	
VT Comm. #:	963	Inspector Signature:		

REINSPECTIONS

INSPECTION TYPE: INT/EXT/OPERATING	DATE Mo/Day/Year	INSPECTOR NAME	VERMONT COMM. #	VIOLATIONS FOUND

**THIS OBJECT MAY NOT BE OPERATED LEGALLY UNLESS THIS CERTIFICATE
 IS POSTED UNDER GLASS IN A CONSPICUOUS PLACE IN ENGINE OR BOILER ROOM**

***Report any accident, incident or explosion to 802-479-4434 ***
 (1-888-870-7888 outside of normal business hours)