

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 18 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 452 South Union 1st Floor Unit # 1

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: AUK080C942D3

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryea

Licensure for plumbing & heating?
Yes No License #: PS163

Certification for gas equipment?
 Yes No Cert#: GB448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: Tag # 5567

C125 1-2
Benoure

TEST 68
DATE 05/18/09
TIME 08:49:32

COMBUSTION

FUEL	NAT	GAS
O2 %		8.7
CO2 %		6.9
CO PPM		1.7
FLUE °F		160.9
INLT °F		52.9
NETT °F		51.0

EFF (G) 88.5
LOSSES 11.5
XAIR % 71.3

CO/CO2 0.0002
CO AIR FREE 29

PRS nPA 0.04

Customer
Appliance
Ref.