

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

5 / 18 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 452 South Union Unit # F2

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

*\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Aux 1006948D3  
Location of Heating System: Basement

System Passed      System Failed      If System Failed, Next Appt:     /     /    

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* Jeff Ryan

Licensure for plumbing & heating?  
Yes      No License #: P5163

Certification for gas equipment?  
X Yes      No Cert#: GB448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: Tag # 5569

---



---

**C125 1-2**  
**Benoure**

TEST      70  
DATE      05/18/09  
TIME      09:02:03

C/

**COMBUSTION**

FUEL	NAT	GAS
O2 %		10.6
CO2 %		5.9
CO ppm		0.0
FLUE °F		37.6
INLT °F		52.9
NETT °F		44.7

EFF (G)	88.4
LOSSES	11.6
XAIR %	102.9

CO/CO2      0.0001  
CO AIR FREE      18

PRS      hPA      0.09

Customer .....

Appliance .....

Ref. ....