

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:  
5 / 18 / 2009

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 452 South Union Unit # 3

**Heating System(s) Type:**

*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**

*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

*\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: AKX080C942D3  
Location of Heating System: Basement

System Passed      System Failed      If System Failed, Next Appt:     /     /    

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* Jeff Ryca

Licensure for plumbing & heating?  
Yes      No License #: PS163

Certification for gas equipment?  
 Yes      No Cert#: 6848

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryca

Comments: TAG # 5568

C125 1-2  
Benoure

TEST      69  
DATE      05/18/09  
TIME      08:52:38

C

COMBUSTION	
.....	
FUEL	NAT GAS
O2 %	10.5
CO2 %	5.3
CO PPM	10
FLUE °F	101.4
INLT °F	52.9
NETT °F	48.5
EFF (G)	88.3
LOSSES	11.7
XAIR %	100.9
CO/CO2	0.0001
CO AIR FREE	20
PRS hPA	0.06

Customer .....

Appliance .....

Ref. ....

.....