

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

8 / 6 / 12

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Richardson, Gene

Address of Inspected Unit: 58 Buell St #1 Unit # 1

Heating System Type: Boiler

Fuel Type: Natural gas

Venting System:

B-Vent

Direct vent

Circulator gaskets

Boiler relief valve

Indirect relief valve

Air vent

Expansion tank

Venting

Make and Model # of :

Boiler: Wm CU-6

Indirect tank: Wm 40

Indirect tank condition: good

Person Conducting Inspection:

Dan Crossman

Licensure for plumbing & heating

License #: PM-3945

Certification for gas equipment

Cert #: GN-2081

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: _____

City tag 15039



BACHARACH, INC.
Fyrite Insight
SN: PX1279

Time: 10:53:46 AM
Date: 08/06/12

CARB

Fuel
Nat Gas

O ₂	4.6 %
CO	8 ppm
Eff	89.6 %
CO ₂	9.2 %
T-STK	132 °F
T-AIR	83.8 °F
EA	25.1 %
CO(O)	11 ppm

Comments: _____

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

8 / 6 / 12

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Richardson, GENE

Address of Inspected Unit: 58 Buell St Unit # 2

Heating System Type: Boiler

Fuel Type: Natural gas

Venting System:

B-Vent
 Direct vent

Circulator gaskets
Boiler relief valve
Indirect relief valve
Air vent
Expansion tank
Venting

Make and Model # of :

Boiler: WM CGS-4

Indirect tank: WM 40

Indirect tank condition: good

Person Conducting Inspection:

Dan Crossman

Licensure for plumbing & heating

License #: PM-3945

Certification for gas equipment

Cert #: GN-2081

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: city tag 15040

BACHARACH

BACHARACH, INC
Fyrite Insight
SN: PX1279

Time: 10:59:27 AM
Date: 08/06/12

CAR

Fuel
Nat Gas

O ₂	
CO	8.4 %
Eff	32 ppm
CO ₂	89.5 %
T-SIK	7.1 %
T-AIR	127 °F
EA	86.6 °F
CO(O)	59.7 %
	54 ppm

Comments:

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.
34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
8 / 6 / 12

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Richards, GENE
Address of Inspected Unit: 58 Buell St Unit # 3

Heating System Type: Boiler
Fuel Type: Natural gas
Venting System:
 B-Vent
 Direct vent

Circulator gaskets
Boiler relief valve
Indirect relief valve
Air vent
Expansion tank
Venting

Make and Model # of :
Boiler: WM Egs 4
Indirect tank: WM 40
Indirect tank condition: good

Person Conducting Inspection:
Dan Crossman
Licensure for plumbing & heating
License #: PM-3945
Certification for gas equipment
Cert #: GN-2081

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments:
city tag 150 38



BACHARACH, INC.
Fyrite Insight
SN: PX1279

CARB# Time: 11:07:23 AM
Date: 08/06/12

Fuel
Nat Gas

O ₂	8.6 %
CO	28 ppm
Eff	89.7 %
CO ₂	6.9 %
T-STK	124 °F
T-AIR	88.9 °F
EA	62.6 %
CO(O)	48 ppm

Comments: