Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection: 5 / 18 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 58 Buell St Unit # 1

Heating System(s) Type: *(Check all that Apply)*
- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- (Boiler)
- Gas Fireplace
- Other

Fuel Type:
- X Natural Gas
- Oil
- Propane

Venting System(s): *(Check all that Apply)*
- (Direct Vent)
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: GV-6

Location of Heating System: Basement utility

(X System Passed) System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryea

Licensure for plumbing & heating?

Yes No License #: PS-163

Certification for gas equipment?

X Yes No Cert#: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: TAg # 5551

C125 1.2
Benoure

TEST 77
DATE 05/18/09
TIME 11:20:08

COMBUSTION

FUEL		NAT GAS
O2	%	5.3
CO2	%	8.5
CO	PPM	06
FLUE	°F	168.7
INLT	°F	63.2
NETT	°F	105.5
EFF (G)		87.3
LOSSES		12.7
XAIR %		33.9
CO/CO2		0.0000
CO AIR FREE		08
PRS	hPA	0.02

Customer

Appliance

Ref.

Benoure Plumbing & Heating, Inc.