

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 18 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 58 Buell St Unit # 2

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: CGS-4-PIN

Location of Heating System: Basement Utility

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?

Yes No License #: PS-163

Certification for gas equipment?

 Yes No Cert#: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: Tag # 5552

C125 1.2
Benoure

TEST 78
DATE 05/18/09
TIME 11:25:27

C.

COMBUSTION		
FUEL	NAT	GAS
O2 %		8.8
CO2 %		6.9
CO PPM		18
FLUE °F	250.0	
INLT °F	63.2	
NETT °F	186.8	
EFF (G)	83.8	
LOSSES	16.2	
XAIR %	72.7	
CO/CO2	0.0002	
CO AIR FREE	31	
PRS hPA	0.05	

Customer: _____
Appliance: _____
Ref.: _____