

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
5 / 18 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 58 Buell St Unit # 3

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: CGS-4-PIN

Location of Heating System: Basement/Utility

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryea

Licensure for plumbing & heating?
Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert#: GB 448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryea

Comments: Tag # 5553

C 125 1.2
Benoure

TEST 79
DATE 05/18/09
TIME 11:32:00

C

COMBUSTION		
.....		
FUEL	NAT	GAS
O2 %		8.5
CO2 %		7.1
CO PPM		26
FLUE °F		246.3
INLT °F		63.2
NETT °F		183.1
EFF (G)		84.2
LOSSES		15.8
XAIR %		68.5
CO/CO2	0.0003	
CO AIR FREE	43	
PRS	hPA	0.10

Customer:
Appliance:
Ref.:
.....