

Benoure Plumbing & Heating, Inc. TAG# 13507

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

10 / 14 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: DENISE VIGNOE

Address of Inspected Unit: 62 HENRY STREET Unit # 1

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: WEIL MCHAIN ESPEG-40

Location of Heating System: BASEMENT

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print)
Scott Gagnon

Licensure for plumbing & heating?

Yes License #: PM-3563

Certification for gas equipment?

Yes Cert #: GB-922

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Scott Gagnon

Comments: _____

C125 1.3

DATE 10/14/11
TIME 13:12:51

FUEL Nat Gas

COMBUSTION

LOG	04
O2 %	8.4
CO2 %	8.2
CO PPM	0.00
FLUE °F	318.8
INLT °F	87.8
NETT °F	243.0

EFF (G)	83.0
LOSSES	17.0
AIR %	44.1

CO/CO2	0.0000
CO AIR FREE	07

PRS Inr20	0.00
-----------	------

.....
Customer

.....
Appliance

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc. TAG# 13508

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

10 / 14 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: DENISE VIGNOE

Address of Inspected Unit: 62 HENRY STREET Unit # 2

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: WEIL MCLAIN EGPE6-40

Location of Heating System: BASEMENT

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print)
Scott Gagnon

Licensure for plumbing & heating?

Yes License #: PM-3563

Certification for gas equipment?

Yes Cert #: GB-922

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Scott Gagnon

Comments: _____

0125 1-3

DATE 10/14/11
TIME 13:17:20

FUEL Nat Gas

COMBUSTION

LOG 05

CO % 6.5

CO2 % 8.2

CO PPM 04

FLUE °F 202.0

INLT °F 67.5

NETT °F 214.8

EFF (G) 83.9

LOSSES 16.1

XBRIR % 43.1

CO/CO2 0.0000

CO AIR FREE 05

PRS 10H2O 0.00

.....
Customer

.....
Appliance

.....
Ref.

.....

.....

.....

.....