

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc. TAG# 13142

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

4 / 12 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 70 Buell St Unit # _____

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Olson GTA - 85

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryer


Licensure for plumbing & heating?
Yes No License #: PS-163

Certification for gas equipment?
Yes No Cert #: GB448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeffrey Ryer

Comments: _____


BACHARACH, INC.
Fyrite Insight
SN: PX1278

Time: 02:55:07 PM
Date: 04/12/11

	Fuel
	Nat Gas
O ₂	11.2 %
CO	21 ppm
Eff	91.0 %
CO ₂	5.5 %
T-STX	108 °F
T-AIR	88.2 °F
EA	101.9 %
CO(O)	45 ppm

Comments: _____

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc. TAG# 13143

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
4 / 12 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gere Richards

Address of Inspected Unit: 72 Buell St Unit # _____

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep.

Model # of Boiler/Furnace/Fireplace: American Standard Aux1 B080M9421AB

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
Yes No License #: PS-163

Certification for gas equipment?
Yes No Cert #: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments:

benoure.....
25.....



BACHARACH, INC.
Fyrite Insight
SN: PX1278

Time: 02:57:55 PM
Date: 04/12/11

Fuel
Nat Gas

O ₂	9.0 %
CO	18 ppm
EFF	96.5 %
CO ₂	6.7 %
T-SIK	97 °F
T-AIR	67.4 °F
EA	66.7 %
CO (O)	32 ppm

Comments:
