

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 18 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 70 Buell St downstairs Apt Unit # _____

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined

need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: GTH - 85

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert#: GB 448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: TAG # 5554

C125 1-2
Benoure

TEST 80
DATE 05/18/09
TIME 11:43:16

COMBUSTION

FUEL	NAT	GAS
O2 %		11.5
CO2 %		5.3
CO ppm		15
FLUE °F		113.6
INLT °F		63.2
NETT °F		50.4
EFF (G)		88.1
LOSSES		11.9
XAIR %		122.3
CO/CO2		0.0002
CO AIR FREE		33
PRS hPA		0.11

Customer
Appliance
Ref: