

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

5 / 18 / 2009

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 72 Buell St. 405LAVES APT Unit # _____

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: _____

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

Jeff Ryan

Licensure for plumbing & heating?

Yes No License #: PS-163

Certification for gas equipment?

Yes No Cert#: GB 448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: TAG #

C125 1.2
Benoure

TEST	81
DATE	05/18/09
TIME	11:53:16

COMBUSTION

FUEL	NAT	GAS
O2 %		9.0
CO2 %		6.8
CO ppm		13
FLUE °F		98.1
INLT °F		63.2
NETT °F		34.9

EFF (G)	89.0
LOSSES	11.0
XAIR %	75.6

CO/CO2	0.0001
CO AIR FREE	22

PRS hPA 0.08

Customer: _____

Appliance: _____

Ref: _____