

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

9 / 23 / 09

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: DENISE VIGNOE

Address of Inspected Unit: 82 ADAMS ST. BURL. Unit # —

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: SLANT FIN V150 EP

Location of Heating System: BASEMENT

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) SCOTT GAGNON

Licensure for plumbing & heating?
 Yes No License #: PM 3563

Certification for gas equipment?
 Yes No Cert #: GB 922

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Scott Gagnon

Comments: _____

C125 1.3
BENOURE PLUMBING HEAT

DATE: 09/23/09
TIME: 11:40:36

FUEL: Nat Gas

COMBUSTION

O2 %	18.7
CO2 %	5.8
CO ppm	10
FLUE °F	246.6
INLT °F	67.9
NETT °F	178.7

EFF (G)	83.2
LOSSES	16.8
XAIR %	104.9

CO/CO2	0.0001
CO AIR FREE	20

PRS inH2O 0.00

Customer

Appliance

Ref.