

Benoure Plumbing & Heating, Inc. TAG# 13505

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
10 / 14 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: DENISE VIGNOE

Address of Inspected Unit: 82 ADAMS STREET Unit # _____

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: TRAVI INDUSTRIES
 Location of Heating System: LIVING ROOM

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print)
 Scott Gagnon

Licensure for plumbing & heating?
 Yes License #: PM-3563

Certification for gas equipment?
 Yes Cert #: GB-922

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Scott Gagnon

Comments: _____

SEEPED
 COMBUSTION
 NO WAY TO TEST

CARBON READING PRINTOUT
 NO ROOM CO
 NO detectable
 CO IN ROOM
 per Scott Gagnon

Benoure Plumbing & Heating, Inc. TAG# 13506

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:

10 / 14 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: DENISE VIGNOE

Address of Inspected Unit: 82 ADAMS STREET Unit # _____

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: SHANT FIN V 150 EP

Location of Heating System: BASEMENT

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print) SCOTT GARNON

Licensure for plumbing & heating?
 Yes No License #: PM 3563

Certification for gas equipment?
 Yes No Cert #: GB922

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Scott Garnon

Comments: _____

C 125 1.8

DATE 10/14/11
 TIME 11:01:51

FUEL Nat Gas

COMBUSTION

LOG 03
 O2 % 19.6
 CO2 % 0.9
 CO ppm 00
 FLUE °F 252.9
 INLT °F 69.0
 NETT °F 188.6

EFF (G) 83.1
 LOSSES 16.9
 XAIR % 102.9

CO/CO2 0.0000
 CO AIR FREE 06

PR3 inH2O 0.00

.....
 Customer |

 Appliance |

 Ref. |

