

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc. TAG# 14621

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
12 / 30 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: GENE RICHARDS

Address of Inspected Unit: 15 WINGBORO TERRACE Unit # _____

Heating System(s) Type: *(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s): *(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: SLANT FIN L30 PT

Location of Heating System: BASEMENT

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print)
Scott Gagnon

Licensure for plumbing & heating?

 Yes License #: PM-3563

Certification for gas equipment?

 Yes Cert #: GB-922

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Scott Gagnon

Comments: _____

0125 1.3

DATE 12/30/11
TIME 13:50:52

FUEL Nat Gas

COMBUSTION

LOG 02

O2 %	13.1
CO2 %	4.4
CO PPM	04
FLUE °F	260.7
INLT °F	28.5
NETT °F	232.2

EFF (G)	78.6
LOSSES	21.4
XAIR %	167.9

CO/CO2	0.0000
CO AIR FREE	10

PRS inH2O 0.03

Customer: _____

Appliance: _____

Ref.: _____

.....