

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:

7-22-10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 18-1 N. Union St Unit # 1

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Wm CGS

Location of Heating System: BTU

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print) David Lachance

Licensure for plumbing & heating?
 Yes No License #: Pm 4084

Certification for gas equipment?
 Yes No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David B. Lachance

Comments: TA # 10433

C-1
 Benoure P+h

TEST 45
 DATE 07/22/10
 TIME 15:49:25

COMBUSTION

FUEL	NAT	GAS
O2 %		10.2
CO2 %		6.1
CO PPM		17
FLUE °F		143.1
INLT °F		82.3
NETT °F		60.8

EFF (G) 87.9
 LOSSES 12.1
 XAIR % 95.3

CO/CO2 0.0002
 CO AIR FREE 33

PRS hPA 0.00

Customer

Appliance

Ref:

Benoure Plumbing & Heating, Inc.