

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7 / 22 / 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 18 N Union St Unit # 2

**Heating System(s) Type:**

*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**

*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Wm 654

Location of Heating System: \_\_\_\_\_

System Passed      System Failed      If System Failed, Next Appt: \_\_\_/\_\_\_/\_\_\_

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* David LaChance

Licensure for plumbing & heating?  
 Yes      No License #: Pm 4084

Certification for gas equipment?  
 Yes      No Cert #: 6N 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David LaChance

Comments: TAG # 10434

**C12**  
Benoure Plm

TEST                    46  
DATE                    07/22/10  
TIME                    15:49:47

**COMBUSTION**

FUEL	NAT	GAS
O2 %		9.3
CO2 %		6.6
CO PPM		19
FLUE %F		183.8
INLT %F		82.3
NETT %F		101.5

EFF (G)                    86.6  
LOSSES                    13.4  
XAIR %                    80.2  
CO/CO2                    0.0002  
CO AIR FREE                34  
PRS hPA                    0.00

.....  
Customer  
.....  
Appliance  
.....  
Ref.  
.....