

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

7, 22, 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 20 N. Union St Unit # 1

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Wm CGS B4

Location of Heating System: _____

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) David Johnson

Licensure for plumbing & heating?
 Yes No License #: Pm 4084

Certification for gas equipment?
 Yes No Cert #: 6N 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David R. Johnson

Comments: TAG # 10435

C 1
Benoure PPH

TEST 47
DATE 07/22/10
TIME 15:50:49

COMBUSTION
.....
FUEL NAT GAS
O2 % 12.3
CO2 % 4.9
CO PPM 14
FLUE %F 187.2
INLT %F 82.3
NETT %F 104.9

EFF (G) 85.4
LOSSES 14.6
XAIR % 143.0

CO/CO2 0.0002
CO AIR FREE 34
PRS hPA 0.00

.....
Customer
.....
Appliance
.....
Ref.
.....

Benoure Plumbing & Heating, Inc.