

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

7, 22, 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 21 Hungerford Ter Unit # —

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Triangle Tube Prestige Solo 175

Location of Heating System: _____

System Passed

System Failed

If System Failed, Next Appt: / /

Company Conduction Inspection:

Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

David R. Lachance

Licensure for plumbing & heating?

Yes

No License #: Pm 4084

Certification for gas equipment?

Yes

No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of
Inspector: David R. Lachance

Comments: TAG# 10424

C 1
Benoure PTH

TEST 35
DATE 07/21/10
TIME 22:44:24

COMBUSTION

FUEL	NAT GAS
O2 %	5.2
CO2 %	8.9
CO ppm	23
FLUE °F	115.8
INLT °F	68.6
NETT °F	47.2
EFF (G)	88.9
LOSSES	11.1
XAIR %	33.1
CO/CO2	0.0002
CO AIR FREE	30
PRS hPa	0.00

Gene Richards
Customer
Triangle Tube
Appliance
21 Hungerford
Ref: