

## Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7, 30, 10

### Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 267 Pearl Suite 10 Unit # \_\_\_\_\_

**Heating System(s) Type:**

*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**

*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Rinnai RHF100L FA-2

Location of Heating System: \_\_\_\_\_

System Passed     System Failed    If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
*(Please Print)*

Licensure for plumbing & heating?

Yes     No License #: Pm 4084

Certification for gas equipment?

Yes     No Cert #: 6N 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David B. Beland

Comments: Could use cleaning & Adjustment

Certification Tag #:

10588

**C125**  
Benoure P+h

TEST                    83  
DATE                    07/30/10  
TIME                    13:56:15

**COMBUSTION**

FUEL	NAT	GAS
O2 %		9.3
CO2 %		6.3
CO ppm		89
FLUE °F		312.3
INLT °F		178.2
NETT °F		134.1
EFF (G)		85.3
LOSSES		14.7
XAIR %		90.0
CO/CO2	0.0014	
CO AIR FREE	169	
PRS	hPA	0.00

Customer .....

Appliance .....

Ref. ....