

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
7, 21, 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 286 Pine St. Unit # 1

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Gas Fireplace

Location of Heating System: LIR

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) David P. Pachana

Licensure for plumbing & heating?
 Yes No License #: Pm 4084

Certification for gas equipment?
 Yes No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David P. Pachana

Comments: TA6# 10178

C
Benoure P+H

TEST 29
DATE 07/20/10
TIME 22:52:08

COMBUSTION

FUEL	NAT	GAS
O2 %		20.9
CO2 %		-0>-
CO PPM		00
FLUE °F		109.1
INLT °F		78.3
NETT °F		38.8

EFF (G) -0>-
LOSSES -0>-
XAIR % -0>-

CO/CO2 0.0000
CO AIR FREE -0>-

PRS hPA 0.00

Customer

Appliance

Ref.